

SCS Global Services does hereby certify that an independent assessment has been conducted on behalf of:

Parterre Flooring Systems

500 Research Drive, Wilmington, MA, United States

For the following product(s):

Vinyl Tile:

Avara Loose Lay, Avara Rigid Core Click with Acoustic Backing, Avara: 2mm Dryback, Vertu Luxury Vinyl Plank, 3.0 MM, InGrained Resilient Plank, 3.0 MM, HardCore Luxury Vinyl Tile -3.0 MM, Fused Luxury Vinyl Tile – 3.0 MM, Storri Luxury Vinyl, 3.0 MM, Custom Luxury Vinyl, Elemental Plank and Tile, 2.5 MM, Reside Domestic Floor, 2.0 MM, Studio Luxury Vinyl Tile, 3.0 MM

The product(s) meet(s) all of the necessary qualifications to be certified for the following claim(s):

FloorScore®

Indoor Air Quality Certified to SCS-EC10.3-2014 v4.0

Conforms to the CDPH/EHLB Standard Method v1.2-2017 (California Section 01350), effective April 1, 2017, for the school classroom and private office parameters when modeled as Flooring.

Measured Concentration of Total Volatile Organic Compounds (TVOC): Less than/equal to 0.5 mg/m³ (in compliance with CDPH/EHLB Standard Method v1.2-2017)

Registration # SCS-FS-03351

Valid from: October 1, 2018 to September 30, 2019

SCS Global Services is currently the only certification body approved by the Resilient Floor Covering Institute (RFCI) to provide FloorScore® product certification; certified products are only listed on the SCS Green Products Guide, <http://www.scsglobalservices.com/certified-green-products-guide>.



A handwritten signature in black ink that reads "Stanley Mathuram".

Stanley Mathuram, PE, Vice President
SCS Global Services
2000 Powell Street, Ste. 600, Emeryville, CA 94608 USA